

AHERA Space #	Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 <sup>st</sup> Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0	1001-01	Kitchen Handwash	SK	N/A		12/9/2025				Sign
0	1001-02	Kitchen 3-Bay	SK	App	<1.0	12/9/2025				-
0	1001-03	Kitchen Island 2-Bay	SK	App	<1.0	12/9/2025				-
0	1001-04	Kitchen Island Handwash	SK	N/A		12/9/2025				Sign
0	1002-01	Faculty Bathroom by Kitchen	SK	N/A		12/9/2025				Sign
0	1003-01	Gym Left	WF	App	<1.0	12/9/2025				-
0	1003-02	Gym Left	BF	App	<1.0	12/9/2025				-
0	1003-03	Gym Right	WF	App	<1.0	12/9/2025				-
0	1004-01	Boy's Bathroom by Gym Left	SK	N/A		12/9/2025				Mixed Valve; Sign
0	1004-02	Boy's Bathroom by Gym Right	SK	N/A		12/9/2025				Mixed Valve; Sign
0	1005-01	Custodial Closet by Gym	SK	N/A		12/9/2025				Sign
0	1006-01	Girl's Bathroom by Gym Left	SK	N/A		12/9/2025				Mixed Valve; Sign
0	1006-02	Girl's Bathroom by Gym Right	SK	N/A		12/9/2025				Mixed Valve; Sign
0	1007-01	Faculty Room	SK	App	<1.0	12/9/2025				-
0	1008-01	Hall by Nurse Left	BF	App	<1.0	12/9/2025				-
0	1008-02	Hall by Nurse Left	WF	App	<1.0	12/9/2025				-
0	1008-03	Hall by Nurse Right	WF	App	<1.0	12/9/2025				-
0	1009-01	Nurse's Office	SK	App	<1.0	12/9/2025				-
0	1009-02	Nurse's Office Bathroom	SK	N/A		12/9/2025				Mixed Valve; Sign
0	1010-01	Faculty Bathroom by Stage	SK	N/A		12/9/2025				Sign

AHERA Space #	Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 <sup>st</sup> Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0	1011-01	Main Office	SK	App	<1.0	12/9/2025				-
0	1011-02	Main Office Bathroom	SK	N/A		12/9/2025				Sign
0	1012-01	Hall by Elevator Left	BF	App	<1.0	12/9/2025				-
0	1012-02	Hall by Elevator Left	WF	App	<1.0	12/9/2025				-
0	1012-03	Hall by Elevator Right	WF	App	<1.0	12/9/2025				-
0	1013-01	Room 107	SK	App	<1.0	12/9/2025				-
0	1013-02	Room 107	WF	App	<1.0	12/9/2025				-
0	1014-01	Room 106	SK	App	<1.0	12/9/2025				-
0	1014-02	Room 106	WF	App	<1.0	12/9/2025				-
0	1015-01	Room 105	SK	App	<1.0	12/9/2025				-
0	1015-02	Room 105	WF	App	<1.0	12/9/2025				-
0	1016-01	Room 104	SK	App	<1.0	12/9/2025				-
0	1016-02	Room 104	WF	App	<1.0	12/9/2025				-
0	1017-01	Room 103	SK	App	<1.0	12/9/2025				-
0	1017-02	Room 103	WF	App	<1.0	12/9/2025				-
0	1018-01	Room 102	SK	App	<1.0	12/9/2025				-
0	1018-02	Room 102	WF	App	<1.0	12/9/2025				-
0	1019-01	Room 101	SK	App	<1.0	12/9/2025				-
0	1019-02	Room 101	WF	App	<1.0	12/9/2025				-
0	1020-01	Room 100	SK	App	<1.0	12/9/2025				-

AHERA Space #	Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 <sup>st</sup> Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0	1020-02	Room 100	WF	App	<1.0	12/9/2025				-
0	1021-01	Library Bathroom	SK	N/A		12/9/2025				Mixed Valve; Sign
0	2001-01	Room 216 Art Counter Left	SK	App	<1.0	12/9/2025				-
0	2001-02	Room 216 Art Counter Right	SK	App	<1.0	12/9/2025				-
0	2002-01	Girl's Bathroom by Room 216	SK	N/A		12/9/2025				Mixed Valve; Sign
0	2003-01	Boy's Bathroom by Room 215	SK	N/A		12/9/2025				Mixed Valve; Sign
0	2004-01	Room 215 Teacher's Station	SK	N/A		12/9/2025				Sign
0	2004-02	Room 215 Counter Left	SK	App		12/9/2025				Non-functional; Sampling required before returning to service
0	2004-03	Room 215 Counter Right	SK	App	<1.0	12/9/2025				-
0	2005-01	Faculty Bathroom by Room 215	SK	N/A		12/9/2025				Sign
0	2006-01	Hall by Room 215 Left	BF	App	<1.0	12/9/2025				-
0	2006-02	Hall by Room 215 Left	WF	App	<1.0	12/9/2025				-
0	2006-03	Hall by Room 215 Right	WF	App	<1.0	12/9/2025				-
0	2007-01	Custodial Closet by Room 215	SS	N/A		12/9/2025				Sign
0	2008-01	Hall by Elevator Left	BF	App	<1.0	12/9/2025				-
0	2008-02	Hall by Elevator Left	WF	App	<1.0	12/9/2025				-
0	2008-03	Hall by Elevator Right	WF	App	<1.0	12/9/2025				-
0	2009-01	Faculty Bathroom by Elevator	SK	N/A		12/9/2025				Mixed Valve; Sign
0	2010-01	Girl's Bathroom by Elevator Left	SK	N/A		12/9/2025				Mixed Valve; Sign
0	2010-02	Girl's Bathroom by Elevator Middle	SK	N/A		12/9/2025				Mixed Valve; Sign

AHERA Space #	Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 <sup>st</sup> Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0	2010-03	Girl's Bathroom by Elevator Right	SK	N/A		12/9/2025				Mixed Valve; Sign
0	2011-01	Boy's Bathroom by Elevator Left	SK	N/A		12/9/2025				Mixed Valve; Sign
0	2011-02	Boy's Bathroom by Elevator Middle	SK	N/A		12/9/2025				Mixed Valve; Sign
0	2011-03	Boy's Bathroom by Elevator Right	SK	N/A		12/9/2025				Mixed Valve; Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 <sup>st</sup> Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0001-01	Yale	SK	App	<1.0	12/9/2025				-
0001-02	Yale	WF	App	<1.0	12/9/2025				-
0002-01	Tuskegee	SK	App	<1.0	12/9/2025				-
0002-02	Tuskegee	WF	App	<1.0	12/9/2025				-
0003-01	Girl's Bathroom by Tuskegee Left	SK	App	<1.0	12/12/2025				-
0003-02	Girl's Bathroom by Tuskegee Right	SK	App	<1.0	12/12/2025				-
0004-01	Hall by Tuskegee	WF	App	<1.0	12/9/2025				-
0004-02	Hall by Tuskegee	BF	App	<1.0	12/9/2025				-
0005-01	Boy's Bathroom by Tuskegee	SK	App	<1.0	12/12/2025				-
0006-01	Custodial Closet by Tuskegee	SS	N/A		12/9/2025				Sign
0007-01	Staff Lounge - Water Purifier	SK	App	<1.0	12/9/2025				-
0007-02	Staff Lounge - Sink Faucet	SK	App	<1.0	12/9/2025				-
0007-03	Staff Lounge Bathroom	SK	App	<1.0	12/12/2025				-
0008-01	LSU	SK	App	1.0	12/9/2025				-
0008-02	LSU	WF	App	5.0	12/9/2025				-
1001-01	Nurse's Office	SK	App	<1.0	12/9/2025				-
1001-02	Nurse's Office	SPY	App	<1.0	12/9/2025				-
1001-03	Nurse's Office Bathroom	SK	App	<1.0	12/12/2025				-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 <sup>st</sup> Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1002-01	Howard	SK	App		12/9/2025				Non-functional; sampling required before returning to service
1002-02	Howard	WF	App		12/9/2025				Non-functional; sampling required before returning to service
1003-01	Harvard	SK	App	<1.0	12/9/2025				-
1003-02	Harvard	WF	App	<1.0	12/9/2025				-
1004-01	Girl's Bathroom by Harvard	SK	App	<1.0	12/12/2025				-
1005-01	Custodial Closet by Harvard	SS	N/A		12/9/2025				Sign
1006-01	Hall by Stony Brook	WF	App	<1.0	12/9/2025				-
1006-02	Hall by Stony Brook	BF	App	<1.0	12/9/2025				-
1007-01	Boy's Bathroom by Stony Brook	SK	App	<1.0	12/12/2025				-
1008-01	Stony Brook	SK	App	<1.0	12/9/2025				-
1008-02	Stony Brook	WF	App	1.0	12/9/2025				-
1009-01	Columbia	SK	App	<1.0	12/9/2025				-
1009-02	Columbia	WF	App	<1.0	12/9/2025				-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 <sup>st</sup> Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0001-01	Outside Spigot - South (Back Door)	SP	N/A	2.0	12/9/2025				Cleaning Only
0001-02	Outside Spigot - East (Left Side of Building)	SP	N/A	2.0	12/9/2025				Cleaning Only
1001-01	Hallway WF - Outside UCLA (Left)	WF	App	<1.0	12/9/2025				-
1001-02	Hallway BF - Outside UCLA	BF	App	<1.0	12/9/2025				-
1001-03	Hallway WF - Outside UCLA (Right)	WF	App	<1.0	12/9/2025				-
1002-01	All Gender Bathroom Left (Left Sink)	SK	N/A		12/9/2025				Mixed Valve; Sign
1002-02	All Gender Bathroom Left (Right Sink)	SK	N/A		12/9/2025				Mixed Valve; Sign
1003-01	All Gender Bathroom Right (Left Sink)	SK	N/A		12/9/2025				Mixed Valve; Sign
1003-02	All Gender Bathroom Right (Right Sink)	SK	N/A		12/9/2025				Mixed Valve; Sign
2001-01	Bathroom - Outside MIT (Left Sink)	SK	N/A		12/9/2025				Mixed Valve; Sign
2001-02	Bathroom - Outside MIT (Right Sink)	SK	N/A		12/9/2025				Mixed Valve; Sign
2002-01	Staff Lounge	SK	App	<1.0	12/9/2025				-
2002-02	Staff Lounge Closet Slop Sink	SS	N/A	1.0	12/9/2025				Sign